



Drinking Taps Stand

Design

- NOTE:**
1. Remove the top soil up to 10cm for all the excavation works.
 2. All ground pipe should all be laid at 50cm and well covered using the dug materials.
 3. Use (HDPE flexible) PE 100 pipe OD63 PN10 wall thickness 5.8mm including all the necessary requirements such as joints, fittings as the main Distribution pipeline.
 3. Use HDPE flexible) PE 100 pipe OD63 PN10 wall thick 3mm (1.0) which extends the pipe to the Handwashing facility and water Tap Stands.
 4. Use well burnt red bricks for the walls and the foundations including the manholes and tank with 1:3 cement mortar mixed ratio.
 5. Fix an L-sharp metallic bar on the manhole and on the manhole cover.
 6. Use 4 inch PVC pipe for the grey water and fill the soakaway pit with charcoal and red bricks.

PROJECT TITLE
Construction drinking water
tap stand in Gumbo Basic
Primary School